



# *COMMONWEALTH of VIRGINIA*

## *DEPARTMENT OF ENVIRONMENTAL QUALITY*

Permit No. **VA0021385**  
Effective Date: **TBD**  
Expiration Date: **TBD**

### AUTHORIZATION TO DISCHARGE UNDER THE VIRGINIA POLLUTANT DISCHARGE ELIMINATION SYSTEM AND THE VIRGINIA STATE WATER CONTROL LAW

In compliance with the provisions of the Clean Water Act as amended and pursuant to the State Water Control Law and regulations adopted pursuant thereto, the following owner is authorized to discharge in accordance with the information submitted with the permit application, and with this permit cover page, Part I – Effluent Limitations and Monitoring Requirements, and Part II – Conditions Applicable To All VPDES Permits, as set forth herein.

Owner Name: Town of Orange  
Facility Name: Town of Orange Wastewater Treatment Plant  
County: Orange  
Facility Location: 119 Belleview Ave., Orange, VA 22960

The owner is authorized to discharge to the following receiving stream:

Stream Name: Rapidan River  
River Basin: Rappahannock River  
River Subbasin: Rapidan – Upper Rappahannock  
Section: 4  
Class: III  
Special Standards: None

---

Thomas A. Faha  
Director, Northern Regional Office  
Department of Environmental Quality

---

Date

## A. Effluent Limitations and Monitoring Requirements

### 1. Outfall 001 – 3.0 MGD Facility

- There shall be no discharge of floating solids or visible foam in other than trace amounts.
- During the period beginning with the permit's effective date and lasting until the expiration date, the permittee is authorized to discharge from Outfall Number 001. Such discharges shall be limited and monitored by the permittee as specified below.

Parameter	Discharge Limitations					Monitoring Requirements		
	<u>Monthly Average</u> <sup>(1)</sup>		<u>Weekly Average</u> <sup>(1)</sup>		<u>Minimum</u>	<u>Maximum</u> <sup>(1)</sup>	<u>Frequency</u>	<u>Sample Type</u>
Flow <sup>(2)</sup> (MGD)	NL		NA		NA	NL	Continuous	TIRE
pH	NA		NA		6.0 S.U.	9.0 S.U.	1/D	Grab
cBOD <sub>5</sub> <sup>(3)</sup>	10 mg/L	110 kg/day	15 mg/L	170 kg/day	NA	NA	3D/W <sup>(9)</sup>	24H-C
Total Suspended Solids (TSS) <sup>(3) (4)</sup>	10 mg/L	110 kg/day	15 mg/L	170 kg/day	NA	NA	5D/W	24H-C
Dissolved Oxygen	NA		NA		6.0 mg/L	NA	1/D	Grab
<i>E. coli</i> (Geometric Mean) <sup>(5)</sup>	126 n/100 mL		NA		NA	NA	1/D	Grab
Total Kjeldahl Nitrogen (TKN)	3.0 mg/L	75 lb/day	4.5 mg/L	110 lb/day	NA	NA	5D/W	24H-C
Nitrate+Nitrite, as N	NL mg/L		NA		NA	NA	1/W	24H-C
Total Nitrogen <sup>(6)</sup>	NL mg/L		NA		NA	NA	1/W	Calculated
Total Nitrogen – Year to Date <sup>(6) (7)</sup>	NL mg/L		NA		NA	NA	1/M	Calculated
Total Nitrogen – Calendar Year <sup>(6) (7)</sup>	4.0 mg/L		NA		NA	NA	1/YR	Calculated
Total Phosphorus	NL mg/L		NA		NA	NA	1/W	24H-C
Total Phosphorus – Year to Date <sup>(7)</sup>	NL mg/L		NA		NA	NA	1/M	Calculated
Total Phosphorus – Calendar Year <sup>(7)</sup>	0.3 mg/L		NA		NA	NA	1/YR	Calculated
Zinc, Total Recoverable	NL µg/L		NL µg/L		NA	NA	1/6M <sup>(10)</sup>	Grab
Copper, Total Recoverable	NL µg/L		NL µg/L		NA	NA	1/6M <sup>(10)</sup>	Grab
Total Hardness (as CaCO <sub>3</sub> )	NL mg/L		NL mg/L		NA	NA	1/6M <sup>(10)</sup>	Grab
Acute/Chronic Toxicity – <i>C. dubia</i> <sup>(8)</sup>	NA		NA		NA	NL	1/YR	24H-C
Acute/Chronic Toxicity – <i>P. promelas</i> <sup>(8)</sup>	NA		NA		NA	NL	1/YR	24H-C

<sup>(1)</sup> See Part I.B.

<sup>(2)</sup> The design flow is 3.0 MGD.

<sup>(3)</sup> At least 85% removal for BOD<sub>5</sub> and TSS shall be attained.

<sup>(4)</sup> TSS shall be expressed as two significant figures.

<sup>(5)</sup> Between 10 AM and 4 PM.

<sup>(6)</sup> Total Nitrogen is the sum of Total Kjeldahl Nitrogen and NO<sub>2</sub>+NO<sub>3</sub> and shall be calculated from the results of those tests.

<sup>(7)</sup> See Part I.B.3 for nutrient reporting requirements.

<sup>(8)</sup> See Part I.D. for toxicity monitoring requirements.

<sup>(9)</sup> See Special Condition 13 for additional instructions regarding effluent monitoring frequencies.

<sup>(10)</sup> Once every six months monitoring periods shall be January to June and July to December. The DMR shall be due the 10<sup>th</sup> of the month following the monitoring periods.

MGD = Million gallons per day.

NA = Not applicable.

NL = No limit; monitor and report.

S.U. = Standard units.

TIRE = Totalizing, indicating and recording equipment.

1/D = Once every day.

3D/W = Three days per week.

5D/W = Five days per week.

1/M = Once every month.

1/6M = Once every six months.

1/YR = Once every calendar year.

24H-C = A flow proportional composite sample collected manually or automatically, and discretely or continuously, for the entire discharge of the monitored 24-hour period. Where discrete sampling is employed, the permittee shall collect a minimum of twenty-four (24) aliquots for compositing. Discrete sampling may be flow proportioned either by varying the time interval between each aliquot or the volume of each aliquot. Time composite samples consisting of a minimum of twenty-four (24) grab samples obtained at hourly or smaller intervals may be collected where the permittee demonstrates that the discharge flow rate (gallons per minute) does not vary by 10% or more during the monitored discharge.

Grab = An individual sample collected over a period of time not to exceed 15 minutes.

### 2. Storm Water Outfalls 001 – 009 – Storm Water Runoff

- There shall be no discharge of floating solids or visible foam in other than trace amounts.
- During the period beginning with the permit's effective date and lasting until the expiration date, the permittee is authorized to discharge storm water runoff from Storm Water Outfalls 001-009.
- There shall be no discharge of process wastewater through these outfalls.

## B. Additional Monitoring Requirements, Quantification Levels and Compliance Reporting

### 1. Quantification Levels

- a. The quantification levels (QL) shall be less than or equal to the following concentrations:

<u>Characteristic</u>	<u>Quantification Level</u>
total suspended solids (TSS)	1.0 mg/L
carbonaceous- biochemical oxygen demand-5 day (cBOD <sub>5</sub> )	2 mg/L
ammonia, as N	0.20 mg/L
total Kjeldahl nitrogen (TKN)	0.50 mg/L
Copper, total recoverable	6.5 mg/L
Zinc, total recoverable	56 mg/L

- b. The QL is defined as the lowest concentration used to calibrate a measurement system in accordance with the procedures published for the method. It is the responsibility of the permittee to ensure that proper quality assurance/quality control (QA/QC) protocols are followed during the sampling and analytical procedures. QA/QC information shall be documented to confirm that appropriate analytical procedures have been used and the required QLs have been attained. The permittee shall use any method in accordance with Part II.A of this permit.

### 2. Compliance Reporting for Parameters in Part I.A.

- a. Monthly Average – Compliance with the monthly average limitations and/or reporting requirements for the parameters listed in Part I.B.1.a. of this permit condition shall be determined as follows: All concentration data below the QL used for the analysis (QL must be less than or equal to the QL listed in Part I.B.1.a above) shall be treated as zero. All concentration data equal to or above the QL used for the analysis shall be treated as it is reported. An arithmetic average shall be calculated using all reported data for the month, including the defined zeros. This arithmetic average shall be reported on the Discharge Monitoring Report (DMR) as calculated. If all data are below the QL used for the analysis, then the average shall be reported as "< QL". If reporting for quantity is required on the DMR and the reported monthly average concentration is < QL, then report "< QL" for the quantity. Otherwise, use the reported concentration data (including the defined zeros) and flow data for each sample day to determine the daily quantity and report the monthly average of the calculated daily quantities.
- b. Weekly Average – Compliance with the weekly average limitations and/or reporting requirements for the parameters listed in Part I.B.1.a. of this permit condition shall be determined as follows: All concentration data below the QL used for the analysis (QL must be less than or equal to the QL listed in Part I.B.1.a. above) shall be treated as zero. All concentration data equal to or above the QL used for the analysis shall be treated as reported. An arithmetic average shall be calculated using all reported data, including the defined zeros, collected within each complete calendar week and entirely contained within the reporting month. The maximum value of the weekly averages thus determined shall be reported on the DMR. If all data are below the QL used for the analysis, then the weekly average shall be reported as "< QL". If reporting for quantity is required on the DMR and the reported weekly average concentration is < QL, then report "< QL" for the quantity. Otherwise use the reported concentration data (including the defined zeros) and flow data for each sample day to determine the daily quantity and report the maximum weekly average of the calculated daily quantities.
- c. Single Datum – Any single datum required shall be reported as "< QL" if it is less than the QL used in the analysis (QL must be less than or equal to the QL listed in Part I.B.1.a above). Otherwise the numerical value shall be reported.
- d. Significant Digits – The permittee shall report at least the same number of significant digits as the permit limit for a given parameter. Regardless of the rounding convention used by the permittee (i.e. 5 always rounding up or to the nearest even number), the permittee shall use the convention consistently and shall ensure that consulting laboratories employed by the permittee use the same convention.

### 3. Nutrient Reporting Calculations for Part I.A.

- a. For each calendar month, the DMR shall show the calendar year-to-date average concentration (mg/L) calculated in accordance with the following formulae:

$$MC_{avg}\text{-YTD} = ( \sum_{(\text{Jan-current month})} MC_{avg} ) \div ( \# \text{ of months } )$$

where:  $MC_{avg}\text{-YTD}$  = calendar year-to-date average concentration (mg/L)  
 $MC_{avg}$  = monthly average concentration (mg/L) as reported on DMR

- b. The total nitrogen and phosphorus average concentrations (mg/L) for each calendar year (AC) shall be shown on the December DMR due January 10<sup>th</sup> of the following year. These values shall be calculated in accordance with the following formulae:

$$AC_{avg} = ( \sum_{(\text{Jan-Dec})} MC_{avg} ) \div 12$$

where:  $AC_{avg}$  = calendar year average concentration (mg/L)  
 $MC_{avg}$  = monthly average concentration (mg/L) as reported on DMR

- c. For total phosphorus, all daily concentration data below the quantification level (QL) for the analytical method used should be treated as half the QL. All daily concentration data equal to or above the QL for the analytical method used shall be treated as it is reported.
- d. For total nitrogen (TN), if none of the daily concentration data for the respective species (i.e. TKN, Nitrates/Nitrites) are equal to or above the QL for the respective analytical methods used, the daily TN concentration value reported shall equal one half of the largest QL used for the respective species. If one of the data is equal to or above the QL, the daily TN concentration value shall be treated as that data point is reported. If more than one of the data is above the QL, the daily TN concentration value shall equal the sum of the data points as reported.

### C. Pretreatment Requirements

1. The permittee's pretreatment program is approved but inactive. The program is an enforceable part of this permit. The permittee shall:
  - a. Within 180 days of the effective date of this permit, submit to the DEQ's Northern Regional Office a survey of all Industrial Users (IUs) discharging to the POTW. The information shall be submitted on the DEQ Discharger Survey Form, or an equivalent form that includes the quantity and quality of the wastewater. Survey results shall include the identification of significant industrial users (SIUs) discharging into the POTW.
  - b. Sludge from the Town of Orange's Water Treatment Plant is received at the facility's bio-augmentation tank. Additionally, plant drains, filter backwash, filtrate from the belt filter press, and decant from aerobic sludge digesters are received at this location. The permittee shall monitor the digester decant from the bio-augmentation tank annually. Results shall be submitted to the DEQ no later than January 10th of the following year. The first test result shall be submitted to DEQ's Northern Regional Office on January 10<sup>th</sup>, 2018.
2. If Categorical Industrial User(s) are identified or if the permittee or DEQ determines that the industrial user(s) have potential to adversely affect the operation of the POTW or cause violation(s) of federal, state or local standards or requirements (see section E.6), the permittee reevaluate all pretreatment program elements and submit to DEQ Northern Regional Office a pretreatment program for approval within one year of written notification by DEQ. The program shall enable the permittee to control by permit the Significant Industrial Users (SIU) discharging wastewater to the treatment works.
3. The approvable pretreatment program submission shall at a minimum contain the following elements:
  - a. Legal authority,
  - b. Program procedures,
  - c. Funding and resources,
  - d. Local limits evaluation and local limits if needed,

- e. Enforcement response plan, and
  - f. List of SIUs.
4. All changes must be approved by DEQ prior to implementation. After all elements are approved, the pretreatment program will be considered active and the requirements below are in effect.
- a. Implement the approved pretreatment program that complies with the Clean Water Act, Water Control Law and State regulations found in 9VAC25-31-730 through 900.
  - b. Submit to DEQ Northern Regional Office an annual report that describes the permittee's program activities over the previous year. The annual report shall be submitted no later than January 31 of each year and must include:
    - 1) An updated list of SIUs showing the categorical standards and local limits applicable to each. The updated list of the SIUs shall note all of the following:
      - a) Facility contact information, including: address, phone and contact information,
      - b) Explanation of SIUs removed from the previous year's list,
      - c) Identification of SIUs subject to Categorical Standards and the applicable standard(s) (i.e., metal finishing);
      - d) Applicable sections of 40 CFR,
      - e) SIUs subject to local limits that are more stringent than Categorical Pretreatment Standards,
      - f) SIUs subject only to local limits,
      - g) Categorical Industrial Users (CIUs) that are subject to reduced reporting requirements under 9VAC25-31-840 E.3.,
      - h) SIUs that are non-significant CIUs, and
      - i) The SIC and NAIC codes for all SIUs and CIUs.
    - 2) A summary of the compliance status of each SIU/IU with pretreatment standards and permit requirements.
    - 3) A summary of the number and types of SIU/IU sampling and inspections performed by the POTW.
    - 4) All information concerning interference, upset, VPDES permit, and/or Water Quality Standards violations directly attributable to SIUs/IUs and associated enforcement actions taken.
    - 5) A description of all enforcement actions taken against SIUs/IUs over the previous 12 months.
    - 6) A summary of any changes to the submitted pretreatment program previously not reported to DEQ Northern Regional Office.
    - 7) A summary of permits issued to SIUs/IUs since the last annual report.
    - 8) POTW and self-monitoring results for SIUs determined to be insignificant non-compliance during the reporting period.
    - 9) The results of POTW influent, effluent and sludge sampling not previously reported to DEQ Northern Regional Office.
    - 10) Copies of newspaper publications of all SIUs significant non-compliance during the reporting period. This is due not later than March 31 of each year.
    - 11) Signature of an authorized response.
  - c. Ensure all SIU permits are issued within 90 days of program approval and return to active status, subsequent SIU permits are reissued in a timely manner, and SIU permits issued or reissued by the POTW are effective and enforceable.
  - d. Ensure all SIUs shall be inspected at least annually.
    - 1) Sampling shall include all regulated parameters and shall be representative of the wastewater discharged.

- 2) Inspection of the SIUs shall cover all areas that could result in wastewater discharge to the treatment works. At a minimum, this would include: manufacturing area, chemical storage areas, pretreatment facilities, spill prevention and control procedures, hazardous waste generation, and the SIU's self-monitoring procedure and records.
  - e. Implement the reporting requirements of Part VII of the VPDES Permit Regulation (9VAC25-31-840).
  - f. All public participation requirements shall be met. The SIUs in significant non-compliance with pretreatment standards and/or requirements for the previous 12 month shall be placed in public notice annually.
5. DEQ may require the POTW to institute changes to the legal authority regarding SIU permits:
- a. If the approved program does not meet the requirements of the Clean Water Act, the State Water Control Law or the state regulations;
  - b. If problem such as interferences, pass-through, violations of water quality standards or sludge contamination develop or continue; and
  - c. If federal, state, or local requirements change.
6. A SIU is an industrial user that:
- a. Has a process wastewater flow (excluding sanitary, non-contact cooling water, boiler blowdown) of 25,000 gallons or more per average workday;
  - b. Contributes a process wastestream which makes up 5% or more of the average dry weather hydraulic or organic capacity of the POTW;
  - c. Is subject to the categorical pretreatment standards; or
  - d. Has significant impact, either singularly or in combination with other SIUs on the treatment works of the quality of its effluent (e.g.; causes pass through or interference).

#### **D. Whole Effluent Toxicity Program Requirements**

##### **1. Biological Monitoring**

- a). In accordance with the schedule in Part I.D.2. below, the permittee shall conduct annual chronic toxicity tests during this permit term. The permittee shall collect 24-hour flow-proportioned composite samples of final effluent at Outfall 001.

The chronic tests to use are:

Chronic 3-Brood Static Renewal Survival and Reproduction Test using *Ceriodaphnia dubia*

Chronic 7-Day Static Renewal Survival and Growth Test using *Pimephales promelas*

These chronic tests shall be conducted in such a manner and at sufficient dilutions (minimum of five dilutions) to determine the "No Observed Effect Concentration" (NOEC) for survival and reproduction or growth. Results which cannot be quantified (i.e. a "less than" NOEC value) are not acceptable and a retest shall be performed. The NOEC, as determined by hypothesis testing, shall be converted to  $TU_c$  (Chronic Toxic Units) for Discharge Monitoring Report (DMR) reporting where  $TU_c = 100/NOEC$ . Report the  $LC_{50}$  at 48 hours and the  $IC_{25}$  with the NOEC's in the test report.

- b). The permittee may provide additional samples to address data variability. These data shall be reported. Test procedures and reporting shall be in accordance with the WET testing methods cited in 40 CFR 136.3.
- c). The test dilutions shall be able to determine compliance with the following endpoints:

Chronic NOEC  $\geq 37\%$ ; equivalent to a  $TU_c \leq 2.70$

- d). The test data will be evaluated statistically for reasonable potential at the conclusion of the test period. The data may be evaluated sooner if requested by the permittee or if toxicity has been noted. Should evaluation of the data indicate that a limit is warranted, a WET limit and compliance schedule will be required.
- e). The permit may be modified or revoked and reissued to include pollutant specific limits in lieu of a WET limit should it be demonstrated that toxicity is due to specific parameters. The pollutant specific limitation shall control the toxicity of the effluent.

## 2. Reporting Schedule

The permittee shall monitor during the specified period; shall report the results on the DMR; and shall supply one copy of the toxicity test report specified in this Whole Effluent Toxicity Program in accordance with the following schedule:

Period	Sampling Period	DMR/Report Submission Dates
Annual 1	April 1, 2017 – June 30, 2017	January 10, 2018
Annual 2	January 1, 2018 – March 31, 2018	January 10, 2019
Annual 3	July 1, 2019 – September 30, 2019	January 10, 2020
Annual 4	October 1, 2020 – December 31, 2020	January 10, 2021

## E. Other Requirements and Special Conditions

### 1. 95% Capacity Reopener

A written notice and a plan of action for ensuring continued compliance with the terms of this permit shall be submitted to the DEQ's Northern Regional Office when the monthly average flow influent to the sewage treatment plant reaches 95% of the design capacity authorized in this permit for each month of any three consecutive month period. The written notice shall be submitted within 30 days and the plan of action shall be received at the DEQ-NRO no later than 90 days from the third consecutive month for which the flow reached 95% of the design capacity. The plan shall include the necessary steps and a prompt schedule of implementation for controlling any current or reasonably anticipated problem resulting from high influent flows. Failure to submit an adequate plan in a timely manner shall be deemed a violation of this permit.

### 2. Indirect Discharges

The permittee shall provide adequate notice to the Department of the following:

- a. Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Section 301 or 306 of Clean Water Act and the State Water Control Law if it were directly discharging those pollutants; and
- b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of this permit.

Adequate notice shall include information on (i) the quality and quantity of effluent introduced into the treatment works, and (ii) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the treatment works.

3. Operations and Maintenance Manual Requirement

The permittee shall maintain a current Operations and Maintenance (O&M) Manual for the treatment works that is in accordance with the Virginia Pollutant Discharge Elimination System Regulations, 9VAC25-31, and the Sewage Collection and Treatment Regulations, 9VAC25-790.

The O&M Manual and subsequent revisions shall include the manual effective date and meet Part II.K.2 and Part II.K.4 Signatory Requirements of the permit. Any changes in the practices and procedures followed by the permittee shall be documented in the O&M Manual within 90 days of the effective date of the changes. The permittee shall operate the treatment works in accordance with the O&M Manual and shall make the O&M manual available to Department personnel for review during facility inspections. Within 30 days of a request by DEQ, the current O&M Manual shall be submitted to the DEQ-NRO for review and approval.

The O&M Manual shall detail the practices and procedures which will be followed to ensure compliance with the requirements of this permit. This manual shall include, but not necessarily be limited to, the following items, as appropriate:

- a. Permitted outfall locations and techniques to be employed in the collection, preservation and analysis of effluent, storm water;
- b. Procedures for measuring and recording the duration and volume of treated wastewater discharged;
- c. Discussion of Best Management Practices, if applicable;
- d. Procedures for handling, storing and disposing of all wastes, fluids and pollutants that will prevent these materials from reaching state waters. List type and quantity of wastes, fluids and pollutants (e.g. chemicals) stored at this facility;
- e. Discussion of treatment works design, treatment works operation, routine preventative maintenance of units within the treatment works, critical spare parts inventory and record keeping;
- f. Plan for the management and/or disposal of waste solids and residues;
- g. Hours of operation and staffing requirements for the plant to ensure effective operation of the treatment works and maintain permit compliance;
- h. List of facility, local and state emergency contacts; and
- i. Procedures for reporting and responding to any spills/overflows/ treatment works upsets.

4. Certificate to Construct/Certificate to Operate Requirements

In accordance with Sewage Collection and Treatment regulation (9VAC25-790), the permittee shall obtain a Certificate to Construct (CTC) and a Certificate to Operate (CTO) from the Department of Environmental Quality prior to constructing wastewater treatment works and operating the treatment works, respectively. Non-compliance with the CTC or CTO shall be deemed a violation of the permit.

5. Licensed Operator Requirement

The permittee shall employ or contract at least one Class I licensed wastewater works operator for this facility. The license shall be issued in accordance with Title 54.1 of the Code of Virginia and Board for Waterworks and Wastewater Works Operators and Onsite Sewage System Professionals Regulations. The permittee shall notify the Department in writing whenever he is not complying, or has grounds for anticipating he will not comply with this requirement. The notification shall include a statement of reasons and a prompt schedule for achieving compliance.

6. Reliability Class

The permitted treatment works shall meet Reliability Class I.



7. Water Quality Criteria Reopener

Should effluent monitoring indicate the need for any water quality-based limitations, this permit may be modified or alternatively revoked and reissued to incorporate appropriate limitations.

8. Sludge Reopener

The Board may promptly modify or revoke and reissue this permit if any applicable standard for sewage sludge use or disposal promulgated under Section 405(d) of the Clean Water Act is more stringent than any requirements for sludge use or disposal in this permit, or controls a pollutant or practice not limited in this permit.

9. Sludge Use and Disposal

The permittee shall conduct all sewage sludge use or disposal activities in accordance with the Sludge Management Plan (SMP) approved with the issuance of this permit. Any proposed changes in the sewage sludge use or disposal practices or procedures followed by the permittee shall be documented and submitted for DEQ-NRO approval 90 days prior to the effective date of the changes. Upon approval, the revised SMP becomes an enforceable part of the permit. The permit may be modified or alternatively revoked and reissued to incorporate limitations or conditions necessitated by substantive changes in sewage sludge use or disposal practices.

10. E3/E4

The annual average concentration limitations for total nitrogen and/or total phosphorus are suspended during any calendar year in which the facility is considered by DEQ to be a participant in the Virginia Environmental Excellence Program in good standing at either the Exemplary Environmental Enterprise (E3) level or the Extraordinary Environmental Enterprise (E4) level, provided that the following conditions have also been met:

- a. The facility has applied for (or renewed) participation, been accepted, maintained a record of sustained compliance and submitted an annual report according to the program guidelines;
- b. The facility has demonstrated that they have in place a fully implemented environmental management system (EMS) with an alternative compliance method that includes operation of installed nutrient removal technologies to achieve the annual average concentration limitations; and
- c. The E3/E4 designation from DEQ and implementation of the EMS has been in effect for the full calendar year.

The annual average concentration limitations for total nitrogen and/or total phosphorus, as applicable, are not suspended in any calendar year following a year in which the facility failed to achieve the annual average concentration limitations as required by b. above.

11. Nutrient Reopener

This permit may be modified or, alternatively, revoked and reissued:

- a. If any approved wasteload allocation procedure, pursuant to Section 303(d) of the Clean Water Act, imposes wasteload allocations, limits or conditions on the facility that are not consistent with the permit requirements;
- b. To incorporate technology-based effluent concentration limitations for nutrients in conjunction with the installation of nutrient control technology, whether by new construction, expansion or upgrade, or
- c. To incorporate alternative nutrient limitations and/or monitoring requirements, should:
  - 1) the State Water Control Board adopt new nutrient standards for the water body receiving the discharge, including the Chesapeake Bay or its tributaries; or
  - 2) a future water quality regulation or statute require new or alternative nutrient control.

## 12. Polychlorinated biphenyl (PCB) Pollutant Minimization Plan

The permittee has completed low-detection level, congener specific monitoring of the effluent for PCBs.

### A. Pollutant Minimization Plan (PMP)

Upon notification from DEQ-NRO that the PCB monitoring results for the effluent indicate a reasonable potential to exceed the water quality criterion the permittee shall submit to DEQ-NRO for review and approval a Pollutant Minimization Plan (PMP) designed to investigate the location and potential reduction of sources of PCBs in the collection system. The PMP shall be submitted within 180 days of the date of the notification letter.

The PMP shall detail the practices and procedures which will be followed to investigate the location and potential reduction of sources of PCBs. This PMP shall include, but not necessarily be limited to, the following items, as appropriate:

- 1) Provide a facility contact for the contents of the PMP and any activities associated with the PMP;
- 2) Provide a proposed implementation schedule for minimization activities and prospective milestones;
- 3) Propose actions for known or probable sources;
- 4) Propose actions to find and control unknown sources;
- 5) Summarize any previous minimization activities;
- 6) Present methods for measuring, demonstrating, and reporting progress;
  - a) May include an evaluation of the total PCBs and/or PCB congener distribution in the initial source intake water to determine the net contributions of PCBs introduced to the treatment works.
  - b) May include raw influent testing using either grab or composite samples as well as sampling upstream in the collection system. Screening methods may be utilized to target specific areas of interest.
  - c) Alternative PCB test methods are acceptable provided analytical sensitivity is sufficient for detection and quantification.
  - d) May perform further monitoring of the final effluent to determine effectiveness of the reduction efforts and to reestablish a new baseline for PCBs in the final effluent.
- 7) Estimate the PCB load reduction provided by treatment; and
- 8) Provide information on continuing assessment of progress, which may include establishment of criteria to evaluate whether the location and potential reduction of PCB sources has been addressed, and whether a more routine follow-up awareness, education, and inspection approach is appropriate.

### B. Pollutant Minimization Plan (PMP) Annual Report

If the permittee is required to implement a PMP in accordance with this special condition, an Annual Report shall be submitted to DEQ-NRO for review and approval by February 10<sup>th</sup> for the previous year's PMP activities.

The Annual Report shall:

- 1) Summarize PMP Achievement for investigating the location and potential reduction of sources of PCBs in the collection system during the past calendar year;
- 2) Address any revisions needed for the PMP for the coming year;
- 3) Address material and process modifications, if applicable;

- 4) Summarize measures taken to address known, probable and potential sources; and
- 5) Discuss incremental and cumulative changes from the baseline loading.

13. Effluent Monitoring Frequency

If the facility permitted herein is issued a Notice of Violation for cBOD5, then the following effluent monitoring frequencies shall revert back to 5D/W effective upon written notice from DEQ and remain in effect until permit expiration.

No other effluent limitations or monitoring requirements are affected by this special condition.

14. Total Maximum Daily Load (TMDL) Reopener

This permit shall be modified or alternatively revoked and reissued if any approved wasteload allocation procedure, pursuant to Section 303(d) of the Clean Water Act, imposes wasteload allocations, limits or conditions on the facility that are not consistent with the permit requirements.

**CONDITIONS APPLICABLE TO ALL VPDES PERMITS****A. Monitoring**

1. Samples and measurements required by this permit shall be taken at the permit designated or approved location and be representative of the monitored activity.
  - a. Monitoring shall be conducted according to procedures approved under Title 40 Code of Federal Regulations Part 136 or alternative methods approved by the U.S. Environmental Protection Agency, unless other procedures have been specified in this permit.
  - b. The permittee shall periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals that will insure accuracy of measurements.
  - c. Samples taken shall be analyzed in accordance with 1VAC30-45, Certification for Noncommercial Environmental Laboratories, or 1VAC30-46, Accreditation for Commercial Environmental Laboratories.
2. Any pollutant specifically addressed by this permit that is sampled or measured at the permit designated or approved location more frequently than required by this permit shall meet the requirements in A 1 a through c above and the results of this monitoring shall be included in the calculations and reporting required by this permit.
3. Operational or process control samples or measurements shall not be taken at the designated permit sampling or measurement locations. Operational or process control samples or measurements do not need to follow procedures approved under Title 40 Code of Federal Regulations Part 136 or be analyzed in accordance with 1VAC30-45, Certification for Noncommercial Environmental Laboratories, or 1VAC30-46, Accreditation for Commercial Environmental Laboratories.

**B. Records**

1. Records of monitoring information shall include:
  - a. The date, exact place, and time of sampling or measurements;
  - b. The individual(s) who performed the sampling or measurements;
  - c. The date(s) and time(s) analyses were performed;
  - d. The individual(s) who performed the analyses;
  - e. The analytical techniques or methods used; and
  - f. The results of such analyses.
2. Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years, the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application. This period of retention shall be extended automatically during the course of any unresolved litigation regarding the regulated activity or regarding control standards applicable to the permittee, or as requested by the Board.

**C. Reporting Monitoring Results**

1. The permittee shall submit the results of the monitoring required by this permit not later than the 10th day of the month after monitoring takes place, unless another reporting schedule is specified elsewhere in this permit.

Monitoring results shall be submitted to:

Department of Environmental Quality – Northern Regional Office (DEQ-NRO)  
13901 Crown Court  
Woodbridge, VA 22193

2. Monitoring results shall be reported on a Discharge Monitoring Report (DMR) or on forms provided, approved or specified by the Department.
3. Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this permit.

#### **D. Duty to Provide Information**

The permittee shall furnish to the Department, within a reasonable time, any information which the Board may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Board may require the permittee to furnish, upon request, such plans, specifications, and other pertinent information as may be necessary to determine the effect of the wastes from this discharge on the quality of state waters, or such other information as may be necessary to accomplish the purposes of the State Water Control Law. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.

#### **E. Compliance Schedule Reports**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.

#### **F. Unauthorized Discharges**

Except in compliance with this permit, or another permit issued by the Board, it shall be unlawful for any person to:

1. Discharge into state waters sewage, industrial wastes, other wastes, or any noxious or deleterious substances; or
2. Otherwise alter the physical, chemical or biological properties of such state waters and make them detrimental to the public health, or to animal or aquatic life, or to the use of such waters for domestic or industrial consumption, or for recreation, or for other uses.

#### **G. Reports of Unauthorized Discharges**

Any permittee who discharges or causes or allows a discharge of sewage, industrial waste, other wastes or any noxious or deleterious substance into or upon state waters in violation of Part II.F.; or who discharges or causes or allows a discharge that may reasonably be expected to enter state waters in violation of Part II.F., shall notify the Department of the discharge immediately upon discovery of the discharge, but in no case later than 24 hours after said discovery. A written report of the unauthorized discharge shall be submitted to the Department, within five days of discovery of the discharge. The written report shall contain:

1. A description of the nature and location of the discharge;
2. The cause of the discharge;
3. The date on which the discharge occurred;
4. The length of time that the discharge continued;
5. The volume of the discharge;
6. If the discharge is continuing, how long it is expected to continue;
7. If the discharge is continuing, what the expected total volume of the discharge will be; and

8. Any steps planned or taken to reduce, eliminate and prevent a recurrence of the present discharge or any future discharges not authorized by this permit.

Discharges reportable to the Department under the immediate reporting requirements of other regulations are exempted from this requirement.

#### **H. Reports of Unusual or Extraordinary Discharges**

If any unusual or extraordinary discharge including a bypass or upset should occur from a treatment works and the discharge enters or could be expected to enter state waters, the permittee shall promptly notify, in no case later than 24 hours, the Department by telephone after the discovery of the discharge. This notification shall provide all available details of the incident, including any adverse affects on aquatic life and the known number of fish killed. The permittee shall reduce the report to writing and shall submit it to the Department within five days of discovery of the discharge in accordance with Part II.I.2. Unusual and extraordinary discharges include but are not limited to any discharge resulting from:

1. Unusual spillage of materials resulting directly or indirectly from processing operations;
2. Breakdown of processing or accessory equipment;
3. Failure or taking out of service some or all of the treatment works; and
4. Flooding or other acts of nature.

#### **I. Reports of Noncompliance**

The permittee shall report any noncompliance which may adversely affect state waters or may endanger public health.

1. An oral report shall be provided within 24 hours from the time the permittee becomes aware of the circumstances. The following shall be included as information which shall be reported within 24 hours under this paragraph:
  - a. Any unanticipated bypass; and
  - b. Any upset which causes a discharge to surface waters.
2. A written report shall be submitted within 5 days and shall contain:
  - a. A description of the noncompliance and its cause;
  - b. The period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and
  - c. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

The Board may waive the written report on a case-by-case basis for reports of noncompliance under Part II.I. if the oral report has been received within 24 hours and no adverse impact on state waters has been reported.

3. The permittee shall report all instances of noncompliance not reported under Parts II, G., H. and I. in writing, at the time the next monitoring reports are submitted. The reports shall contain the information listed in Part II.I.2.

NOTE: The immediate (within 24 hours) reports required in Parts II, G., H. and I. may be made to the Department's Northern Regional Office at (703) 583-3800 or online at

<http://www.deq.virginia.gov/Programs/PollutionResponsePreparedness/MakingaReport.aspx>.

For reports outside normal working hours, leave a message and this shall fulfill the immediate reporting requirement. For emergencies, the Virginia Department of Emergency Services maintains a 24-hour telephone service at 1-800-468-8892.

**J. Notice of Planned Changes**

1. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
  - a. The permittee plans alteration or addition to any building, structure, facility, or installation from which there is or may be a discharge of pollutants, the construction of which commenced:
    - 1) After promulgation of standards of performance under Section 306 of Clean Water Act which are applicable to such source; or
    - 2) After proposal of standards of performance in accordance with Section 306 of Clean Water Act which are applicable to such source, but only if the standards are promulgated in accordance with Section 306 within 120 days of their proposal;
  - b. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations nor to notification requirements specified elsewhere in this permit; or
  - c. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
2. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

**K. Signatory Requirements**

1. Applications. All permit applications shall be signed as follows:
  - a. For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
    - 1) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or
    - 2) The manager of one or more manufacturing, production, or operating facilities, provided the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures;
  - b. For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or
  - c. For a municipality, state, federal, or other public agency: by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a public agency includes:
    - 1) The chief executive officer of the agency, or
    - 2) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.

2. Reports, etc. All reports required by permits, and other information requested by the Board shall be signed by a person described in Part II.K.1., or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a. The authorization is made in writing by a person described in Part II.K.1.;
  - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.); and
  - c. The written authorization is submitted to the Department.
3. Changes to authorization. If an authorization under Part II.K.2. is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Part II.K.2. shall be submitted to the Department prior to or together with any reports, or information to be signed by an authorized representative.
4. Certification. Any person signing a document under Parts II, K.1. or K.2. shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

#### **L. Duty to Comply**

The permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the State Water Control Law and the Clean Water Act, except that noncompliance with certain provisions of this permit may constitute a violation of the State Water Control Law but not the Clean Water Act. Permit noncompliance is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if this permit has not yet been modified to incorporate the requirement.

#### **M. Duty to Reapply**

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee shall apply for and obtain a new permit. All permittees with a currently effective permit shall submit a new application at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Board. The Board shall not grant permission for applications to be submitted later than the expiration date of the existing permit.

#### **N. Effect of a Permit**

This permit does not convey any property rights in either real or personal property or any exclusive privileges, nor does it authorize any injury to private property or invasion of personal rights, or any infringement of federal, state or local law or regulations.



**O. State Law**

Nothing in this permit shall be construed to preclude the institution of any legal action under, or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any other state law or regulation or under authority preserved by Section 510 of the Clean Water Act. Except as provided in permit conditions on "bypassing" (Part II.U.), and "upset" (Part II.V.) nothing in this permit shall be construed to relieve the permittee from civil and criminal penalties for noncompliance.

**P. Oil and Hazardous Substance Liability**

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Sections 62.1-44.34:14 through 62.1-44.34:23 of the State Water Control Law.

**Q. Proper Operation and Maintenance**

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes effective plant performance, adequate funding, adequate staffing, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by the permittee only when the operation is necessary to achieve compliance with the conditions of this permit.

**R. Disposal of Solids or Sludges**

Solids, sludges or other pollutants removed in the course of treatment or management of pollutants shall be disposed of in a manner so as to prevent any pollutant from such materials from entering state waters.

**S. Duty to Mitigate**

The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

**T. Need to Halt or Reduce Activity not a Defense**

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

**U. Bypass**

1. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts II, U.2. and U.3.
2. Notice
  - a. Anticipated bypass. If the permittee knows in advance of the need for a bypass, prior notice shall be submitted, if possible at least ten days before the date of the bypass.
  - b. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Part II.I.
3. Prohibition of bypass.
  - a. Bypass is prohibited, and the Board may take enforcement action against a permittee for bypass, unless:
    - 1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;

- 2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
  - 3) The permittee submitted notices as required under Part II.U.2.
- b. The Board may approve an anticipated bypass, after considering its adverse effects, if the Board determines that it will meet the three conditions listed above in Part II.U.3.a.

## **V. Upset**

1. An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of Part II.V.2. are met. A determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is not a final administrative action subject to judicial review.
2. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - a. An upset occurred and that the permittee can identify the cause(s) of the upset;
  - b. The permitted facility was at the time being properly operated;
  - c. The permittee submitted notice of the upset as required in Part II.I.; and
  - d. The permittee complied with any remedial measures required under Part II.S.
3. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

## **W. Inspection and Entry**

The permittee shall allow the Director, or an authorized representative, upon presentation of credentials and other documents as may be required by law, to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
4. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act and the State Water Control Law, any substances or parameters at any location.

For purposes of this section, the time for inspection shall be deemed reasonable during regular business hours, and whenever the facility is discharging. Nothing contained herein shall make an inspection unreasonable during an emergency.

## **X. Permit Actions**

Permits may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

**Y. Transfer of Permits**

1. Permits are not transferable to any person except after notice to the Department. Except as provided in Part II.Y.2., a permit may be transferred by the permittee to a new owner or operator only if the permit has been modified or revoked and reissued, or a minor modification made, to identify the new permittee and incorporate such other requirements as may be necessary under the State Water Control Law and the Clean Water Act.
2. As an alternative to transfers under Part II.Y.1., this permit may be automatically transferred to a new permittee if:
  - a. The current permittee notifies the Department at least 30 days in advance of the proposed transfer of the title to the facility or property;
  - b. The notice includes a written agreement between the existing and new permittees containing a specific date for transfer of permit responsibility, coverage, and liability between them; and
  - c. The Board does not notify the existing permittee and the proposed new permittee of its intent to modify or revoke and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement mentioned in Part II.Y.2.b.

**Z. Severability**

The provisions of this permit are severable, and if any provision of this permit or the application of any provision of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.